

电力工业电气设备质量检验测试中心

Quality Inspection and Test Center
for Equipment of Electric Power



(2013) 检字

JHG545 号

检测报告

Inspection Report



地 址： 湖北省武汉市洪山区珞喻路 143 号
邮 编： 430074
电 话： 4006565689
传 真： (027) 59832255
网 址： China-qite.sgepri.sgcc.com.cn

Quality Inspection and Test Center for Equipment of Electric Power Inspection Report

2013JH6545

1. Client

Guangdong Sihui Instrument Transformer Works Co Ltd.

2. Description of Sample

Name of test sample: Voltage transformer

Type : JSQXF-252

Sample NO.: V1308220001

Manufacturer: Guangdong Sihui Instrument Transformer Works Co Ltd.

Date of Manufacture: July-2013

Sampling way: offer by client

3. Inspection Standards/References

GB 1207—2006 Voltage transformers

DL/T 726—2000 Specification of voltage transformer for electrical power for order

IEC 60044—2: 2003 Instrument transformers-Part 2: Voltage transformers

4. Category of Inspection

Routine Test /Type Test

5. Inspection Dates:

2013 - 08 - 13 ~ 2013 - 08 - 22

6. Conclusion:

Voltage transformer with the type of JSQXF-252 offered by Guangdong Sihui Instrument Transformer Works Co Ltd. meets the requirements of the corresponding items of the standards GB1207-2006, etc.

7. Valid time : 5 years

Note: This English report is written at request of the client. In the event of any difference in meanings of the text, the Chinese report shall take precedence over the English version.

Inspected by:

王焱 刘西超

Checked by:

郭之勤

Examined and verified by:

岑华

Approved by:

岑华

Date:

2013-09-22

8. Testing Item and Conclusion

No.	Item	Reference standard	Test result	Conclusion
1	Inspection semblance and verification of terminal markings	The nameplate, sign, earthing terminal, terminal marking shall meet the requirements.	OK	Pass
2	Power-frequency withstand test on secondary windings	Applied voltage on winding-to-winding and winding-to-earth shall be 3kV/50Hz/1min	Test voltage 3kV/50Hz/1min No puncture occurs.	Pass
3	Power frequency withstand test on earthed terminal of primary winding	Applied voltage between earthed terminal of primary winding and earth shall be 5kV/50Hz/1min	Test voltage 5kV/50Hz/1min No puncture occurs.	Pass
4	Power-frequency withstand test on primary windings	Applied voltage on every primary winding to secondary windings and earth shall be 460kV/150Hz/40 s	Test voltage: 460kV/150Hz/40s No puncture occurs. Note: The object is a voltage transformer for GIS. No atmosphere correction needed. Ambient temperature: 29°C Relative humidity: 50% Atmosphere pressure: 101.2kPa	Pass
5	Partial discharge measurement	Testing frequency 150 Hz Pre-stress voltage 460 kV Test voltage 302 kV PD ≤ 5 pC	Testing frequency 150 Hz Pre-stress voltage 460 kV Test voltage 302 kV PD Phase A 4 pC Phase B 4 pC Phase C 4 pC Background PD 1.8 pC Ambient temperature 29°C Relative humidity 50 %	Pass
6	Measurement of Excitation	Providing the test data	Details in appendix No. C	Pass
7	Determination of errors	The errors of the second windings should meet the requirement of classes 0.2/3P/3P.	The errors of secondary winding are measured at rated frequency and rated power factor within rated burden. Details in appendix No. D	Pass
8	Measurement of DC resistances of secondary windings	Providing the test data	Phase A AN: 36.53 kΩ 1a1n: 36.45 mΩ 2a2n: 35.20 mΩ dadn: 76.67 mΩ Phase B AN: 35.81 kΩ 1a1n: 36.39 mΩ 2a2n: 35.58 mΩ dadn: 77.44 mΩ Phase C AN: 36.10 kΩ 1a1n: 37.60 mΩ 2a2n: 36.82 mΩ dadn: 78.00 mΩ Ambient temperature 27 °C	—

No.	Item	Reference standard	Test result	Conclusion
9	Temperature rise test	<p>The temperature rise of windings cannot exceed 75K under the voltage of 1.0Un.</p> <p>The temperature rise of windings cannot exceed 75K under the voltage of 1.2Un.</p> <p>The temperature rise of windings cannot exceed 10K under the voltage of 1.5Un 30s (beginning from the normality).</p>	<p>Rated primary voltage on phase A,B,C, the transformer should be tested with 1aln connect to a burden corresponding to the thermal limiting output (1000VA) at a unity power factor without loading the residual voltage winding, the values of temperature rise are shown as follows.</p> <p>Phase A AN: 17 K 1aln: 29 K 2a2n: 29 K</p> <p>Phase B AN: 17 K 1aln: 29 K 2a2n: 29 K</p> <p>Phase C AN: 17 K 1aln: 30 K 2a2n: 29 K</p> <p>Ambient temperature 27 °C</p> <p>Under the voltage of 1.2Un and rated burden on phase A,B,C, the values of temperature rise are shown as follows.</p> <p>Phase A AN: 4 K 1aln: 5 K 2a2n: 6 K</p> <p>Phase B AN: 4 K 1aln: 5 K 2a2n: 5 K</p> <p>Phase C AN: 4 K 1aln: 5 K 2a2n: 5 K</p> <p>Ambient temperature 27°C</p> <p>The voltage of 1.5Un is applied to primary winding on phase A,B,C for 30s beginning from the normality when the secondary windings load rated burden. After every part reaching a steady state, the values of temperature rise are shown as follows.</p> <p>Phase A AN: 0.4 K 1aln: 0.5 K 2a2n: 0.5 K dadn: 0.6 K</p> <p>Phase B AN: 0.4 K 1aln: 0.5 K 2a2n: 0.5 K dadn: 0.6 K</p> <p>Phase C AN: 0.4 K 1aln: 0.5 K 2a2n: 0.5 K dadn: 0.6 K</p> <p>Ambient temperature 27 °C Details in appendix No.E.</p>	Pass

No.	Item	Reference standard	Test result	Conclusion
10	Lightning impulse test and chopped lighting impulse test	Applied voltage on primary winding to secondary windings and earth shall be Standard LI: 1050kV waveform: 1.2/50 μ s positive impulses: 15 times negative impulses: 15 times Standard LI-chopped: 220kV waveform: (2~5) μ s negative impulses: 2 times	Fifteen consecutive LI in positive and negative polarities and two LI-chopped in negative polarity were applied at primary terminal. Details in appendix No.F. No puncture occurs.	Pass
11	Short-circuit withstand capability test	The rated voltage 57.7V is applied to secondary windings for 1.0s when primary winding is connected with the ground. There shall be no electrical and mechanical damage	Phase A 1a1n Secondary voltage: 57.8 V Secondary current: 1082 A Phase B 1a1n Secondary voltage: 57.7 V Secondary current: 1082 A Phase C 1a1n Secondary voltage: 57.7 V Secondary current: 1061 A Durative time: 1.05 s Waveform in appendix No. G There is no electrical and mechanical damage. Note The windings are copper and the current density in the windings is 18.2A/mm ² . The second windings are copper and the current density in the windings is 120A/mm ² .	Pass
12	Power-frequency withstand test on secondary windings(retrial)	Applied voltage on winding-to-winding and winding-to-earth shall be 3kV/50Hz/1min.	Winding-to-winding and winding-to-earth Test voltage: 3kV/50Hz/1min No puncture occurs.	Pass
13	Power frequency withstand test on earthed terminal of primary winding(retrial)	Applied voltage between earthed terminal of primary winding and earth shall be 5kV/50Hz /1min	Test voltage 5kV/50Hz/1min No puncture occurs.	Pass
14	Power-frequency withstand test on primary windings (retrial)	Applied voltage on primary winding to secondary windings and earth shall be 414kV/150Hz/40s	Test voltage: 414kV/150Hz/40s No puncture occurs.	Pass
15	Partial discharge measurement (retrial)	Testing frequency 150 Hz Pre-stress voltage 414 kV Test voltage 302 kV PD ≤ 5 pC	Testing frequency 150 Hz Pre-stress voltage 414 kV Test voltage 302 kV PD Phase A 4 pC Phase B 4 pC Phase C 4 pC Background PD 1.9 pC Ambient temperature 32 $^{\circ}$ C Relative humidity 60 %	Pass

No.	Item	Reference standard	Test result	Conclusion
16	Measurement of Excitation (retrial)	Providing the test data	Magnetizing current at rated voltage Phase A 9.01 A Phase B 8.99 A Phase C 8.81 A	—
17	Determination of errors (retrial)	The errors of the second windings shall meet the requirement of class 0.2	Details in appendix No.H	Pass
18	Transmitted overvoltage measurement	A low-voltage impulse ($T_1=10ns \pm 20\%$, $T_2 \geq 100ns$) shall be applied between one of the primary terminals and earth, the value of the transmitted overvoltage does not exceed 1.6kV.	the value of the transmitted overvoltage 1196V~1397V, Details in appendix No. I	Pass
19	The gas seal test	The relative ratio of gas giving off in one year should not exceed 0.5% at the rated pressure of 0.55MPa.	The relative ratio of gas giving off in one year doesn't exceed 0.1%	Pass
20	Measurement of the water contained in gas	The water contained in gas shall be less than 150 μ L/L	The water contained in gas is 62 μ L/L	Pass
21	Short time power frequency withstand test on primary winding in the case of no displayed pressure	In the case of no displayed pressure, The test voltage (190kV) shall be applied between the terminal of the primary wind and earth for 5min. The terminals of the secondary windings shall be connected to earth..	In the case of no displayed pressure Test voltage 190kV/5min No disruptive discharge occurs	Pass
22	Inspection of core	Clear, no displacement, no distortion. The sizes should accord with the requirements of design.	OK Photographs in appendix No.K	Pass

- Note
1. Main test circuits, Details in appendix No. J.
 2. The tests of 1~18 items were performed in the pressure of 0.5MPa. The tests of 19, 20 items were performed in the rated pressure of 0.55MPa.
 3. The object is a three-phase community voltage transformer for GIS, the photograph of semblance in appendix No. K.

Appendix No.A Main characteristic Parameters of the Sample

Description: Voltage transformer

Sample No.: V1308220001

Type: JSQXF-252

Highest voltage for equipment: 252kV

Rated voltage: $220/\sqrt{3}$ kV

Rated frequency: 50 Hz

Rated transformation ratio: $220/\sqrt{3} / 0.1/\sqrt{3} / 0.1/\sqrt{3} / 0.1$ kV

Rated insulation level : 252/460/1050kV

Thermal limiting output: $3 \times 2 \times 1000$ VA (Phase A,B,C in 1a1n ,2a2n with 1000 VA burden)

Date of Manufacture: July-2013

Secondary windings(A)		$\frac{1a1n}{0.2}$	$\frac{2a2n}{3P}$	$\frac{dadn}{3P}$
Accuracy class				
Rated burden(VA)	1a1n	2.5~100	100	100
	2a2n	150	150	150
Power factor=0.8	dadn	/	300	300

Secondary windings(B)		$\frac{1a1n}{0.2}$	$\frac{2a2n}{3P}$	$\frac{dadn}{3P}$
Accuracy class				
Rated burden(VA)	1a1n	2.5~100	100	100
	2a2n	150	150	150
Power factor=0.8	dadn	/	/	300

Secondary windings(C)		$\frac{1a1n}{0.2}$	$\frac{2a2n}{3P}$	$\frac{dadn}{3P}$
Accuracy class				
Rated burden(VA)	1a1n	2.5~100	100	100
	2a2n	150	150	150
Power factor=0.8	dadn	/	300	300

Appendix No.B Parameters of the main equipment


No.	Description/Type	Serial No.	Technical parameter	Accuracy class or uncertainty	Calibration institution	Valid date
1	Voltage transformer for measuring service HJ-220	#12006 (YQ367)	$(110\sqrt{3} - 220\sqrt{3}) \text{ kV}$	0.02	National center for high voltage measurement	2014.10.29
2	Instrument transformer test set HEF-H	#KI020 (YQ320)	100, $100/\sqrt{3} \text{ V}$	2	National center for high voltage measurement	2013.12.04
3	Current transformer for measuring service HL-61C	#3089 (YQ608)	$(5-5000)/5, 1\text{A}$	0.01	National center for high voltage measurement	2014.07.04
4	Partial discharge detector JFD-251	#20051112 (YQ381)	$(0.5 \sim 2000) \text{ pC}$	10	N National center for high voltage measurement	2014.08.29
5	Impulse voltage generator	#17020001003 (SB202)	4000kV, 300kJ	/	Quality inspection and testing station for instrument transformers	2014.05.08

Appendix No.C Measurement of Excitation

Percentage of rated secondary voltage(%)		20	50	80	100	120	150
No-load secondary current (A)	A I _{ln}	1.85	4.55	7.20	9.00	10.60	10.41
No-load loss (W)		/	/	/	50	/	/
No-load secondary current (A)	B I _{ln}	1.85	4.56	7.20	9.00	10.61	10.40
No-load loss (W)		/	/	/	50	/	/
No-load secondary current (A)	C I _{ln}	1.85	4.55	7.21	8.80	10.61	10.60
No-load loss (W)		/	/	/	48	/	/
Ambient temperature		29℃		Relative humidity		50%	

Appendix No.D Determination of errors

1. Test circuits



TT: Testing transformer

Tx: Object voltage transformer

T₀: standard voltage transformer

2. Test result

Secondary windings	Accuracy class	Error	Percentage of rated current(phase A)			Burden (VA/cos φ)		
			80	100	120	1a1n	2a2n	
1a1n	02	Ratio error (%)	-0.12	-0.12	-0.14	100	150	
		Phase displacement(°)	-3	-3	-3	0.8	0.8	
		Ratio error (%)	+0.16	+0.16	+0.14	2.5	0	
		Phase displacement(°)	0	0	0	0.8		
Secondary windings	Accuracy class	Error	Percentage of rated current(phase A)			Burden (VA/cos φ)		
			2	5	100	1a1n	2a2n	dadn
2a2n	3P	Ratio error (%)	-0.14	-0.14	-0.16	100	150	0
		Phase displacement(°)	-2	-2	-2	0.8	0.8	
		Ratio error (%)	+0.14	+0.14	+0.14	0	37.5	0
		Phase displacement(°)	+1	+1	+1		0.8	
Secondary windings	Accuracy class	Error	Percentage of rated current(phase A)			Burden (VA/cos φ)		
			150			1a1n	2a2n	dadn
2a2n	3P	Ratio error (%)	-0.26			100	150	300
		Phase displacement(°)	-1			0.8	0.8	0.8
		Ratio error (%)	+0.04			0	37.5	0
		Phase displacement(°)	+1				0.8	


Secondary windings	Accuracy class	Error	Percentage of rated current(phase A)			Burden (VA/cos ϕ)		
			2	5	100	1a1n	2a2n	dadn
dadn	3P	Ratio error (%)	-0.44	-0.44	-0.46	100	150	0
		Phase displacement(°)	-5	-5	-5	0.8	0.8	
		Ratio error (%)	-0.24	-0.24	-0.26	0	0	0
		Phase displacement(°)	+1	+1	+1			
Secondary windings	Accuracy class	Error	Percentage of rated current(phase A)			Burden (VA/cos ϕ)		
			150			1a1n	2a2n	dadn
dadn	3P	Ratio error (%)	-1.00			100	150	300
		Phase displacement(°)	-6			0.8	0.8	0.8
		Ratio error (%)	-0.46			0	0	75
		Phase displacement(°)	+1					0.8
Secondary windings	Accuracy class	Error	Percentage of rated current(phase B)			Burden (VA/cos ϕ)		
			80	100	120	1a1n	2a2n	
1a1n	0.2	Ratio error (%)	-0.12	-0.12	-0.14	100	150	
		Phase displacement(°)	-3	-3	-3	0.8	0.8	
		Ratio error (%)	+0.16	+0.16	+0.14	2.5	0	
		Phase displacement(°)	0	0	0	0.8		
Secondary windings	Accuracy class	Error	Percentage of rated current(phase B)			Burden (VA/cos ϕ)		
			2	5	100	1a1n	2a2n	dadn
2a2n	3P	Ratio error (%)	-0.14	-0.14	-0.16	100	150	0
		Phase displacement(°)	-2	-3	-3	0.8	0.8	
		Ratio error (%)	+0.14	+0.14	+0.14	0	37.5	0
		Phase displacement(°)	+2	+2	+2		0.8	
Secondary windings	Accuracy class	Error	Percentage of rated current(phase B)			Burden (VA/cos ϕ)		
			150			1a1n	2a2n	dadn
2a2n	3P	Ratio error (%)	-0.24			100	150	300
		Phase displacement(°)	-1			0.8	0.8	0.8
		Ratio error (%)	+0.04			0	37.5	0
		Phase displacement(°)	+2				0.8	
Secondary windings	Accuracy class	Error	Percentage of rated current(phase B)			Burden (VA/cos ϕ)		
			2	5	100	1a1n	2a2n	dadn
dadn	3P	Ratio error (%)	-0.44	-0.44	-0.48	100	150	0
		Phase displacement(°)	-5	-5	-5	0.8	0.8	
		Ratio error (%)	-0.26	-0.26	-0.26	0	0	0
		Phase displacement(°)	+1	+1	+1			

Secondary windings	Accuracy class	Error	Percentage of rated current(phase B)			Burden (VA/cos φ)		
			150			1a1n	2a2n	dadn
dadn	3P	Ratio error (%)	-1.00			100	150	300
		Phase displacement(°)	-7			0.8	0.8	0.8
		Ratio error (%)	-0.48			0	0	75
		Phase displacement(°)	+1					0.8
Secondary windings	Accuracy class	Error	Percentage of rated current(phase C)			Burden (VA/cos φ)		
			80	100	120	1a1n	2a2n	
1a1n	0.2	Ratio error (%)	-0.12	-0.12	-0.14	100	150	
		Phase displacement(°)	-3	-3	-2	0.8	0.8	
		Ratio error (%)	+0.16	+0.16	+0.16	2.5	0	
		Phase displacement(°)	0	0	0	0.8		
Secondary windings	Accuracy class	Error	Percentage of rated current(phase C)			Burden (VA/cos φ)		
			2	5	100	1a1n	2a2n	dadn
2a2n	3P	Ratio error (%)	-0.14	-0.14	-0.16	100	150	0
		Phase displacement(°)	-2	-2	-2	0.8	0.8	
		Ratio error (%)	+0.14	+0.14	+0.12	0	37.5	0
		Phase displacement(°)	+1	+1	+1		0.8	
Secondary windings	Accuracy class	Error	Percentage of rated current(phase C)			Burden (VA/cos φ)		
			150			1a1n	2a2n	dadn
2a2n	3P	Ratio error (%)	-0.26			100	150	300
		Phase displacement(°)	-1			0.8	0.8	0.8
		Ratio error (%)	+0.04			0	37.5	0
		Phase displacement(°)	+1				0.8	
Secondary windings	Accuracy class	Error	Percentage of rated current(phase C)			Burden (VA/cos φ)		
			2	5	100	1a1n	2a2n	dadn
dadn	3P	Ratio error (%)	-0.46	-0.46	-0.46	100	150	0
		Phase displacement(°)	-6	-5	-5	0.8	0.8	
		Ratio error (%)	-0.26	-0.26	-0.26	0	0	0
		Phase displacement(°)	0	+1	+1			
Secondary windings	Accuracy class	Error	Percentage of rated current(phase C)			Burden (VA/cos φ)		
			150			1a1n	2a2n	dadn
dadn	3P	Ratio error (%)	-0.98			100	150	300
		Phase displacement(°)	-6			0.8	0.8	0.8
		Ratio error (%)	-0.48			0	0	75
		Phase displacement(°)	+1					0.8
Ambient temperature		30 °C			Relative humidity		60 %	


Appendix No. E Temperature rise test

Phase A 1.0Un

Temperature-rising curve of AN
The thermal resistance of $R_2=38890\ \Omega$




Temperature-rising curve of IaIn
The thermal resistance of $R_2=0.040479\ \Omega$




Phase B 1.0Un

Temperature-rising curve of AN
The thermal resistance of $R_2=38138 \Omega$




Temperature-rising curve of 1a1n The thermal resistance of $R_2=0.040360 \Omega$




Phase C 1.0Un

Temperature-rising curve of AN The thermal resistance of $R_2=38429 \Omega$



Temperature-rising curve of 1a1n The thermal resistance of $R_2=0.041828 \Omega$




Appendix No.F Lightning impulse test and chopped lightning impulse test

1、 Atmosphere conditions

Ambient temperature 29℃

Relative humidity 70 %

2、 Test circuits

 R_{S1} : front resistance R_p : tail resistance g_1 : discharging sphere gap g_2 : chopping sphere gap C_1 : front capacitor C_2 : tail capacitor Z_1, Z_2 : divider T_x : object

V: voltage meter

3、 Test results

Phase A

No.	The standard voltage (peak) (kV)	Waveform of voltage	The test voltage (peak) (kV)	The chopped time(μ s)	Wave-form No.	Result	Remarks
1	525	Pos.LI	512	/	1	OK	/
2	1050	Pos.LI	1041	/	2	OK	/
3	1050	Pos.LI	1047	/	3	OK	/
4	1050	Pos.LI	1053	/	4	OK	/
5	1050	Pos.LI	1053	/	5	OK	/
6	1050	Pos.LI	1055	/	6	OK	/
7	1050	Pos.LI	1055	/	7	OK	/
8	1050	Pos.LI	1056	/	8	OK	/
9	1050	Pos.LI	1054	/	9	OK	/
10	1050	Pos.LI	1054	/	10	OK	/
11	1050	Pos.LI	1056	/	11	OK	/
12	1050	Pos.LI	1056	/	12	OK	/
13	1050	Pos.LI	1060	/	13	OK	/
14	1050	Pos.LI	1060	/	14	OK	/

No.	The standard voltage (peak) (kV)	Waveform of voltage	The test voltage (peak) (kV)	The chopped time(μ s)	Wave-form No.	Result	Remarks
15	1050	Pos.LI	1062	/	15	OK	/
16	1050	Pos.LI	1062	/	16	OK	/
17	525	Neg.LI	540	/	17	OK	/
18	1050	Neg.LI	1056	/	18	OK	/
19	604	Neg.LI-chopped	611	4.04	19	OK	/
20	1208	Neg.LI-chopped	1200	4.08	20	OK	/
21	1208	Neg.LI-chopped	1209	3.82	21	OK	/
22	1050	Neg.LI	1063	/	22	OK	/
23	1050	Neg.LI	1058	/	23	OK	/
24	1050	Neg.LI	1058	/	24	OK	/
25	1050	Neg.LI	1058	/	25	OK	/
26	1050	Neg.LI	1058	/	26	OK	/
27	1050	Neg.LI	1059	/	27	OK	/
28	1050	Neg.LI	1059	/	28	OK	/
29	1050	Neg.LI	1059	/	29	OK	/
30	1050	Neg.LI	1059	/	30	OK	/
31	1050	Neg.LI	1059	/	31	OK	/
32	1050	Neg.LI	1058	/	32	OK	/
33	1050	Neg.LI	1060	/	33	OK	/
34	1050	Neg.LI	1060	/	34	OK	/
35	1050	Neg.LI	1061	/	35	OK	/

Phase B

No.	The standard voltage (peak) (kV)	Waveform of voltage	The test voltage (peak) (kV)	The chopped time(μ s)	Wave-form No.	Result	Remarks
1	525	Pos.LI	545	/	1	OK	/
2	1050	Pos.LI	1038	/	2	OK	/
3	1050	Pos.LI	1051	/	3	OK	/
4	1050	Pos.LI	1051	/	4	OK	/
5	1050	Pos.LI	1052	/	5	OK	/
6	1050	Pos.LI	1052	/	6	OK	/

No.	The standard voltage (peak) (kV)	Waveform of voltage	The test voltage (peak) (kV)	The chopped time(μ s)	Wave-form No.	Result	Remarks
7	1050	Pos.LI	1052	/	7	OK	/
8	1050	Pos.LI	1052	/	8	OK	/
9	1050	Pos.LI	1053	/	9	OK	/
10	1050	Pos.LI	1052	/	10	OK	/
11	1050	Pos.LI	1053	/	11	OK	/
12	1050	Pos.LI	1054	/	12	OK	/
13	1050	Pos.LI	1053	/	13	OK	/
14	1050	Pos.LI	1053	/	14	OK	/
15	1050	Pos.LI	1053	/	15	OK	/
16	1050	Pos.LI	1054	/	16	OK	/
17	525	Neg.LI	545	/	17	OK	/
18	1050	Neg.LI	1043	/	18	OK	/
19	604	Neg.LI-chopped	615	3.81	19	OK	/
20	1208	Neg.LI-chopped	1203	3.57	20	OK	/
21	1208	Neg.LI-chopped	1203	3.20	21	OK	/
22	1050	Neg.LI	1060	/	22	OK	/
23	1050	Neg.LI	1060	/	23	OK	/
24	1050	Neg.LI	1059	/	24	OK	/
25	1050	Neg.LI	1059	/	25	OK	/
26	1050	Neg.LI	1060	/	26	OK	/
27	1050	Neg.LI	1060	/	27	OK	/
28	1050	Neg.LI	1060	/	28	OK	/
29	1050	Neg.LI	1062	/	29	OK	/
30	1050	Neg.LI	1062	/	30	OK	/
31	1050	Neg.LI	1061	/	31	OK	/
32	1050	Neg.LI	1060	/	32	OK	/
33	1050	Neg.LI	1061	/	33	OK	/
34	1050	Neg.LI	1061	/	34	OK	/
35	1050	Neg.LI	1060	/	35	OK	/

Phase C


No.	The standard voltage (peak) (kV)	Waveform of voltage	The test voltage (peak) (kV)	The chopped time(μ s)	Wave-form No.	Result	Remarks
1	525	Pos.LI	530	/	1	OK	/
2	1050	Pos.LI	1043	/	2	OK	/
3	1050	Pos.LI	1045	/	3	OK	/
4	1050	Pos.LI	1044	/	4	OK	/
5	1050	Pos.LI	1045	/	5	OK	/
6	1050	Pos.LI	1046	/	6	OK	/
7	1050	Pos.LI	1045	/	7	OK	/
8	1050	Pos.LI	1044	/	8	OK	/
9	1050	Pos.LI	1046	/	9	OK	/
10	1050	Pos.LI	1045	/	10	OK	/
11	1050	Pos.LI	1046	/	11	OK	/
12	1050	Pos.LI	1045	/	12	OK	/
13	1050	Pos.LI	1045	/	13	OK	/
14	1050	Pos.LI	1046	/	14	OK	/
15	1050	Pos.LI	1046	/	15	OK	/
16	1050	Pos.LI	1046	/	16	OK	/
17	525	Neg.LI	528	/	17	OK	/
18	1050	Neg.LI	1054	/	18	OK	/
19	604	Neg.LI-chopped	612	3.76	19	OK	/
20	1208	Neg.LI-chopped	1200	3.40	20	OK	/
21	1208	Neg.LI-chopped	1209	3.42	21	OK	/
22	1050	Neg.LI	1053	/	22	OK	/
23	1050	Neg.LI	1043	/	23	OK	/
24	1050	Neg.LI	1055	/	24	OK	/
25	1050	Neg.LI	1050	/	25	OK	/
26	1050	Neg.LI	1051	/	26	OK	/
27	1050	Neg.LI	1048	/	27	OK	/
28	1050	Neg.LI	1053	/	28	OK	/
29	1050	Neg.LI	1055	/	29	OK	/
30	1050	Neg.LI	1054	/	30	OK	/
31	1050	Neg.LI	1056	/	31	OK	/
32	1050	Neg.LI	1054	/	32	OK	/


No.	The standard voltage (peak) (kV)	Waveform of voltage	The test voltage (peak) (kV)	The chopped time(μ s)	Wave-form No.	Result	Remarks
33	1050	Neg.LI	1054	/	33	OK	/
34	1050	Neg.LI	1056	/	34	OK	/
35	1050	Neg.LI	1056	/	35	OK	/

4、Conclusion Pass


Phase A

Appendix referential waveform (1.52/49.0 μ s)







No.13




No.14




No.15




No.16




No.17




No.18




No.19




No.20




No.21




No.22




No.23




No.24




No.25




No.26




No.27




No.28



No.29





No.30




Phase B

Appendix referential waveform (1.52/48.9 μ s)










Phase C

Appendix referential waveform (1.52/49.0 μs)








Appendix No.G Endurance of short circuit

1. Test circuits




TV: AC voltage regulator
 TA: Measuring current transformer
 Tx: Object voltage transformer

TT: Transformer
 OSC: Recording oscillograph

S: Switch
 V: Voltage meter


2. Test Waveform



U

I($R_0=0.12 \Omega$)


Phase A



U

I($R_0=0.12 \Omega$)

Phase B



U

I($R_0=0.12 \Omega$)

Phase C

Appendix No.H Determination of errors(retrial)

Secondary windings	Accuracy class	Error	Percentage of rated current (A)			Burden (VA/cos ϕ)	
			80	100	120	1a1n	2a2n
1a1n	0.2	Ratio error (%)	-0.12	-0.12	-0.14	100	150
		Phase displacement(')	-3	-3	-3	0.8	0.8
		Ratio error (%)	+0.16	+0.16	+0.14	2.5	0
		Phase displacement(')	0	0	0	0.8	
Secondary windings	Accuracy class	Error	Percentage of rated current (B)			Burden (VA/cos ϕ)	
			80	100	120	1a1n	2a2n
1a1n	0.2	Ratio error (%)	-0.12	-0.12	-0.14	100	150
		Phase displacement(')	-3	-3	-2	0.8	0.8
		Ratio error (%)	+0.16	+0.16	+0.14	2.5	0
		Phase displacement(')	0	0	0	0.8	
Secondary windings	Accuracy class	Error	Percentage of rated current (C)			Burden (VA/cos ϕ)	
			80	100	120	1a1n	2a2n
1a1n	0.2	Ratio error (%)	-0.12	-0.12	-0.14	100	150
		Phase displacement(')	-2	-2	-2	0.8	0.8
		Ratio error (%)	+0.16	+0.16	+0.14	2.5	0
		Phase displacement(')	0	+1	+1	0.8	
Ambient temperature		32 °C			Relative humidity		60 %


Appendix No. 1 Transmitted overvoltage measurement

1、 Atmosphere conditions

Room temperature 29 °C

Relative humidity 70 %

2、 Test circuits




3、 Test results

Secondary windings	Waveform T_1 μs T_2 μs	Applying impulse-voltage on primary winding (U_1) (kV)	The peak-voltage of secondary windings (U_2) (V)	The peak-voltage of transmission over-voltage (U_s) (V)	Waveform No.	
1a1n	A	T_1 10.1 T_2 >100	213	0.8	1236	1
2a2n		T_1 10.1 T_2 >100	220	0.8	1196	2
dadn		T_1 10.1 T_2 >100	216	0.9	1371	3
1a1n	B	T_1 10.1 T_2 >100	214	0.9	1384	4
2a2n		T_1 10.1 T_2 >100	214	0.9	1384	5
dadn		T_1 10.1 T_2 >100	214	0.8	1230	6
1a1n	C	T_1 10.0 T_2 >100	216	0.9	1371	7
2a2n		T_1 10.0 T_2 >100	212	0.9	1397	8
dadn		T_1 10.0 T_2 >100	220	0.8	1196	9


Note $U_s = \frac{U_2}{U_1} \times U_p$ $U_p = 1.6 \frac{\sqrt{2}U_m}{\sqrt{3}}$

4. Conclusion Pass




Appendix No. J Main test circuits

Figure 1—Power-frequency withstand test on primary windings



- C_a —Object
- C_k —Coupling capacitor
- Z —filter (there is no need if C_k is capacitance of testing transformer)



- T—testing transformer
- C_a —Object
- C_k —Coupling capacitor
- M—measurement of partial discharge
- Z_m —testing impedance
- Z —filter (there is no need if C_k is capacitance of testing transformer)

Appendix No. K Photograph of semblance



电压互感器

执行标准 GB 1207-2006 考制00000724号

型号 JSQXF-252 额定频率 50 Hz 出厂编号 V1308220001

额定绝缘水平 252/460/1050 kV 电压因数 1.5Un/30s

额定压力/报警压力 0.55/0.50 MPa 温度 -25~40 °C

绝缘等级 E 海拔 ≤1000 m 相数 三相 户外

变比 kV/V	端子	准确度	容量 VA	极限输出 VA
220 $\sqrt{3}$ /100 $\sqrt{3}$	1a-1n	0.2	100	1000
220 $\sqrt{3}$ /100 $\sqrt{3}$	2a-2n	3P	150	1000
220 $\sqrt{3}$ /100	da-dn	3P	300	-

SF₆重量 36 kg 总重量 1050 kg 制造日期 2013年7月

广东四会互感器厂有限公司